



Bucknalls Lane, Garston
Watford, Herts WD25 9BA
Tel: 01923 665300
Fax: 01923 665301
email: clientservices@bbacerts.co.uk
website: www.bbacerts.co.uk

BRITISH BOARD OF AGRÉMENT TEST REPORT 62163

RES-TEC LIMITED – FLEXITEC SYSTEM 2020

CONTENTS

- 1 Report conditions
- 2 Watertightness

Approved By:

Nicola George
(Test Technician)

Date: 04 August 2017

Authorised By:

Sean Whitehead
(Test Team Manager)

Date: 07 August 2017

On behalf of the British Board of Agrément

Client: Res-Tec Limited
Unit 25
Castle Park Industrial Estate
Flint
CH6 5XA
UK
Requested by: Allison Moffat
Job No: T1 62163
Work Period: August 2017

1 REPORT CONDITIONS

1.1 This Report:

- relates only to the product/system and sample/specimen thereof named and described herein
- relates only to the specified tests and test conditions described herein
- is issued only to the company, firm, organisation or person named herein — no other company, firm, organisation or person may hold this Report or claim that it has been issued to them
- has to be read, considered and used as a whole document — it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English Law.

1.2 No verification of any of the materials, samples, specimens, information, data or documents supplied to the BBA has been made, except where otherwise stated.

1.3 Publications, documents, specifications and similar matter that are referred to herein, are those that were current at the date of issue of this Report, except where otherwise stated.

1.4 The BBA has used due skill, care and diligence in preparing this Report, but no warranty is given or implied.

1.5 In issuing this Report, the BBA is not responsible; and is excluded from any liability to any company, firm, organisation or person; for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system
- individual installations of the product/system, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product/system is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product/system, including its manufacture, supply, installation, use, maintenance and removal.

1.6 This Report does not constitute or indicate any approval, certification or endorsement of the product/system.

2 WATERTIGHTNESS

2.1 Method

In accordance with BS EN 1928 : 2000 *Flexible sheets for waterproofing – Bitumen, plastic and rubber sheets for roof waterproofing – Determination of watertightness*, Method A.

Carried out using a pressure of 10 kPa.

2.2 Samples

BBA Ref/Lot	Quantity	Description ⁽¹⁾
T1/62163/1	6	Flexitec 2020 system, dark grey, free film 250x250

2.3 Results

Specimen	Result
1	Pass, no leakage or colour change
2	Pass, no leakage or colour change
3	Pass, no leakage or colour change